

(i) Each pressure-type wire connector and lug must comply with UL 486A. No wire nuts may be used.

(j) Each terminal block must have terminal screws 6-32 or larger.

(k) Each wire connector used in conjunction with screw-type terminal blocks must be of the captive type such as the ring or the flanged-spade type.

(1) No cable may be spliced in—

(1) A hazardous location; or

(2) Another location, except—

(i) A cable installed in a subassembly may be spliced to a cable installed in another subassembly;

(ii) For a vessel receiving alterations, a cable may be spliced to extend a circuit;

(iii) A cable of large diameter or exceptional length may be spliced to facilitate its installation.

(iv) A cable may be spliced to replace a damaged section of itself if, before replacement of the damaged section, the insulation resistance of the remainder of the cable is measured, and the condition of the insulation is unimpaired.

(m) All material in a cable splice must be chemically compatible with other material in the splice and with the materials in the cable.

(n) Ampacities for conductors must comply with Section 310-15 of the NEC (NFPA 70), or with IEEE Standard 45, as appropriate.

(o) Each conductor must be sized so that the voltage drop at the load terminals does not exceed 10 percent.

(p) Each metallic covering of armored cable must—

(1) Be electrically continuous; and

(2) Be grounded at each end of the run to the—

(i) Hull (on a metallic vessel); or

(ii) Common ground plate (on a non-metallic vessel); and

(3) Have final sub-circuits grounded at the supply end only.

(q) Each portable or temporary electric cord or cable must be constructed and used in compliance with the requirements of §111.60-13 of this chapter for flexible electric cord or cable.

§ 129.350 Batteries—general.

(a) Wherever a battery is charged, there must be natural or induced ventilation to dissipate the gases generated.

(b) Each battery must be located as high above the bilge as practicable within the space the battery is located in and be secured to protect against shifting due to roll, pitch, and heave motions or vibration of the vessel, and free from exposure to splash or spray of water.

(c) Each battery must be accessible for maintenance and removal.

(d) Each connection to a battery terminal must be made with a permanent connector, rather than with spring clips or other temporary clamps.

(e) Each battery must be mounted in a tray lined with, or constructed of, lead or other material resistant to damage by the electrolyte.

(f) Each battery charger must have an ammeter connected in the charging circuit.

(g) Unless the battery is adjacent to its distribution panel or switchboard that distributes power to the lighting, motor, and appliance circuits, the battery leads must have fuses in series with and as close as practicable to the battery.

(h) Each battery used for starting an engine must be located as close as possible to the engine or engines served.

§ 129.353 Battery categories.

This section applies to batteries installed to meet the requirements of §129.310(a) for secondary sources of power to vital loads.

(a) *Large.* A large battery-installation is one connected to a battery charger having an output of more than 2 kW, computed from the highest possible charging current and rated voltage of the battery installed.

(b) *Small.* A small battery-installation is one connected to a battery charger having an output of 2 kW or less, computed from the highest possible charging current and rated voltage of the battery installed.

§ 129.356 Battery installations.

(a) *Large.* Each large battery-installation must be located in a locker, room, or enclosed box dedicated solely to the storage of batteries. Ventilation must be provided in accordance with §111.15-10 of this chapter. Electrical equipment located within the battery

§ 129.360

enclosure must be approved by an independent laboratory for hazardous locations of Class I, Division 1, Group B, and must meet subpart 111.105 of this chapter.

(b) *Small.* Each small battery-installation must be located in a well-ventilated space and protected from falling objects. No small battery-installation may be in a closet, storeroom, or similar space.

§ 129.360 Semiconductor-rectifier systems.

(a) Each semiconductor-rectifier system must have an adequate heat-removal system to prevent overheating.

(b) If a semiconductor-rectifier system is used in a propulsion system or in another vital system, it must—

(1) Have a current-limiting circuit;

(2) Have external overcurrent protection; and

(3) Comply with Sections 4/5.84.2 and 4/5.84.4 of the “Rules for Building and Classing Steel Vessels” of the American Bureau of Shipping.

§ 129.370 Equipment grounding.

(a) On a metallic vessel each metallic enclosure and frame of electrical equipment must be permanently grounded to the hull. On a nonmetallic vessel each enclosure and frame of electrical equipment must be bonded to each other and to a common ground by a conductor not normally carrying current.

(b) Each metallic case of instruments must be grounded. So must each secondary winding of instrument transformers.

(c) Each equipment grounding conductor must be sized to comply with section 250–95 of NEC (NFPA 70).

(d) Each nonmetallic mast and topmast must have a lightning-ground conductor.

§ 129.375 System grounding.

(a) If a grounded distribution system is provided, there must be only one connection to ground, regardless of the number of power sources. This connection must be at the main switchboard.

(b) On each metallic vessel, a grounded distribution system must be grounded to the hull. On each nonmetallic vessel, the neutral of a grounded system must be connected to a common

46 CFR Ch. I (10–1–13 Edition)

ground plate, except that no aluminum grounding conductors may be used.

(c) On each nonmetallic vessel with a grounded distribution system, the common ground plate must have—

(1) Only one connection to the main switchboard; and

(2) The connection to itself readily accessible for checking.

(d) On each nonmetallic vessel with a ground plate provided for radio equipment, the plate must be connected to the common ground plate.

(e) Each insulated grounding-conductor of a cable must be identified by one of the following means:

(1) Wrapping of the cable with green braid or green insulation.

(2) Stripping of the insulation from the entire exposed length of the grounding-conductor.

(3) Marking of the exposed insulation of the grounding-conductor with green tape or green adhesive labels.

(f) No vessel’s hull may carry current as a conductor except for—

(1) An impressed-current cathodic-protection system; or

(2) A battery system to start an engine.

(g) No cable armor may be used to ground electrical equipment or systems.

(h) Each receptacle outlet and attachment plug, for a portable lamp, tool, or similar apparatus operating at 100 or more volts, must have a grounding-pole and a grounding-conductor in the portable cord.

§ 129.380 Overcurrent protection.

(a) Overcurrent protection must be provided for each ungrounded conductor, to open the electric circuit if the current reaches a value that causes an excessive or dangerous temperature in the conductor or its insulation.

(b) Each conductor of a control, interlock, or indicator circuit, such as a conductor for an instrument, pilot light, ground-detector light, or potential transformer, must be protected by an overcurrent device.

(c) Each generator must be protected by an overcurrent device set at a value not exceeding 115 percent of the generator’s full-load rating.